

iTrust
Centre for Research
in Cyber Security



Briefing to IDS Teams 16 August 2024

Supported by



National
Cybersecurity R&D
Laboratory



AGENDA

- **IDS Timeline**
- **Administration Procedures**
- **CISS Setup**
- **Network Architecture**
- **IDS Performance analysis**
- **Q&A**

IDS TIMELINE (REVISED)

Online briefing:	16 Aug 2024 (10:30 AM)
Onsite installation period:	19 – 30 Aug 2024
Active network scanning period:	2 - 12 Sep 2024
Baselining session:	13 - 18 Sep 2024
Evaluation session:	19 - 20 Sep 2024

ONSITE INSTALLATION PERIOD

Book max 2 days to set up your systems at iTrust

- 19 - 30 Aug 2024 (excluding weekend and 3rd Sep)
- 09:00 to 18:00
- [Booking Link](https://tinyurl.com/ciss24ids) (https://tinyurl.com/ciss24ids)

Deliver systems to SWaT (from 19 August)

- Building 2, Level 7, Room 14,
8 Somapah Road,
Singapore 487372
- POC: Andrew (9745 0741)

ONSITE INSTALLATION PERIOD

We will provide

- Power socket
- Network traffic from all testbeds via Ethernet.
- 1 x RJ45 port from the aggregator
- Up to 700 Mbps throughput

Bring your own

- Power strips
- Cables
- SIM device for remote accessible

ACTIVE NETWORK SCANNING PERIOD

Book one session

- 2 - 12 Sep 2024 (Onsite)
- 0900 - 1100, 1300 - 1500, 1500 - 1700
- [Booking Link](https://tinyurl.com/ciss24ids) (https://tinyurl.com/ciss24ids)

We will provide

- Access to the network
- dedicated slot per vendor

Bring your own tools

CISS Active Network Scanning

Booking Slots for Active Network Scanning ... [Read more](#)

2 hours

DATE

< > July 2023

Su	Mo	Tu	We	Th	Fr	Sa
						1
2	3	4	5	6	7	8
9	10	11	12	13	14	15
16	17	18	19	20	21	22
23	24	25	26	27	28	29
30	31					

TIME

9:00 AM 1:00 PM 3:00 PM

ⓘ All times are in (UTC+08:00) Kuala Lumpur, Singapore

BASELINING SESSIONS DETAILS

Period

- 13 - 18 Sep 2024
- 10:00 – 17:00 hrs

Configuration

- Concurrent session across all vendors
- Testbeds will running in normal mode

Please Note

- Actions taken by the operator made known
- No active scanning during this period
- No further devices be added after 10 Sep

REQUESTS

ADD YOUR DETAILS

First and last name *

Email *

Address

Phone number *

Notes

PROVIDE ADDITIONAL INFORMATION

Any other special requests for your IDS?

Does your IDS do only passive monitoring?

Any other requests, please do through the booking link

- E.g. 2 x RJ45 ports, request for historian data
- We will do our best to accommodate the request
- Please also indicate which vendor you are affiliated with as part of your name
- E.g. Ivan Christian (iTrust) → In the name field.




SETUP FOR CISS 2024 EXECUTION


THE EIGHTH INTERNATIONAL CRITICAL INFRASTRUCTURE SECURITY SHOWDOWN





CISS NETWORK ARCHITECTURE






Date	Time	Event	Title	Sector
06/07/22	10:48:11.984	Alarm on - not ack.	GSW3 Alarm activated Network	
06/07/22	10:48:11.972	Alarm on - not ack.	SSW1 Alarm activated Network	
06/07/22	10:48:11.977	Alarm on - not ack.	SSW3 Alarm activated Network	
06/07/22	10:48:11.499	Alarm on - not ack.	TSW3 Alarm activated Network	

6 Active Alarms

0 Ack. Alarms




Total Apparent Power VA

Total Apparent Power Consumed VA

Total Available Apparent Power VA

ELECTRIC GRID NETWORK



PLCs: WAGO

Subnet:

1. 172.18.0.0/16
2. 172.16.0.0/16

Protocols:


1. IEC 61850
 - a. MMS
 - b. GOOSE
2. Modbus TCP

System Overview

Date / Time 17/10/2019 9:48:55 AM

Current User SUTD_ITRUST

Overview	Raw Water	Pre-Treatment	Ultra-Filtration	De-Chlorination	Reverse Osmosis	RO Product
System Architecture	Trends	Alarms & Events	Summary			Legend




Plant Control Ready

Start Stop Auto Manual Reset

100	▲	17/10/2019 5:06:04 AM	AIT503_AH	RO Feed Conductivity Transmitter: Alarm High	Reverse Osmosis System
100	▲	16/10/2019 7:14:47 PM	AIT504_AH	RO Permeate Conductivity Transmitter: Alarm High	Reverse Osmosis System



Water Treatment Network Diagram



PLC: Allen-Bradley
Subnet: 192.168.1.0/24
Protocol:


I. EtherNet/IP (ENIP)

System Overview

Date / Time 8/11/2021 12:16:36 pm


Current User WADI-EWS\SIU

System Overview	Primary Grid	Elevated Reservoir	Booster Station	Consumer	Return Water
System Architecture	Trends	Alarms & Events	Summary		Legend




Water Distribution Network

Zone C-Plant Network



PLC: Allen-Bradley
Subnet: 192.168.1.0/24
Protocols:

1. EtherNet/IP (ENIP)
2. Modbus TCP



MONITORING GUIDELINES

Should monitor

- 192.168.1.0/24
- 172.18.0.0/16
- 172.16.0.0/16

Need not monitor

- Hypervisors
- 10.0.0.0/8
- 169.254.0.0/16

REPORTING OF INCIDENTS

Each IDS will get a Live excel spreadsheet

- Fields as below
- Custom fields allowed
- Update as alerts are found
- Spreadsheets will be open till end of 20 Sep

No	Period Start Time	Period End Time	Source IP/Port	Destination IP/Port	Protocol	Severity Level	OT Variable	OT Value	Impact Assessment	Description
e.g.	d-mmm-yy hh:mm:ss	d-mmm-yy hh:mm:ss	IP/Port	IP/Port	TCP, UDP, ICMP, etc.	critical, high, medium, low	-	-	Discovery (Network Enumeration)	-
e.g. 1	15-Aug-24 15:00:00	15-Aug-24 15:00:30	192.168.200.123	192.168.200.234 (HMI)	ICMP	Medium	-	-	Discovery (Network Enumeration)	-
e.g. 2	15-Aug-24 16:00:00	15-Aug-24 16:30:30	192.168.200.123/52112	192.168.200.56/44818	ENIP	High	Valve_1	Open	Damage to property	-

IDS PERFORMANCE ANALYSIS

19 - 27 Sep 2024 (Red Team Execution)

19 - 20 Sep 2024 (Evaluation)



IDS PERFORMANCE ANALYSIS

- Each of the IDS will be evaluated against a set of red team attacks
- OT Attacks that purely affect the processes of the system will be launched during the evaluation
- Reports will be given to the committee live during the execution of the attacks
- Performance will be analysed based on the DRACE metrics
- Evaluation Dates
 - 19 to 20 Sep 2024

Performance Metrics

Score	Components	Readability	Accuracy	Responsiveness	Disruptivity
4	<ul style="list-style-type: none"> Identified components attacked. Identified Source and Destination IP Addresses Failure type Reason for Failure 	Flesch-Kincaid Score 70.0 - 100.0	90.0 - 100.0% Accuracy and 0.0 - 10.0 % False Alarm Rate	Responds within 5 seconds	0% plant downtime
3	<ul style="list-style-type: none"> Identified components attacked. Identified Source and Destination IP Addresses Failure type 	Flesch-Kincaid Score 50.0 - 69.9	70.0 - 89.9% Accuracy and 10.1 - 30.0 % False Alarm Rate	Responds within 30 seconds	1-20% plant downtime
2	<ul style="list-style-type: none"> Identified all components attacked. Identified Source and Destination IP Addresses 	Flesch-Kincaid Score 30.0 - 49.9	30.0 - 49.9% Accuracy and 50.1 - 70.0 % False Alarm Rate	Responds within 5 minutes	21 –50% plant downtime
1	<ul style="list-style-type: none"> Identified all components attacked. 	Flesch-Kincaid Score 10.0 - 29.9	10.0 - 29.9% Accuracy and 70.1 - 90.0 % False Alarm Rate	Responds within 60 minutes	51 – 99% plant downtime
0	Nothing identified	Flesch-Kincaid Score 0.0 - 9.9	0.0 - 9.9% Accuracy and 90.1 - 100.0 % False Alarm Rate	No response	100% plant downtime

COMPONENT IDENTIFICATION

- 4Points
 - Source and Destination Indicator Identified (1 point)
 - Component Identified (1 point)
 - Failure type (1 point)
 - Reason for Failure (1 point)
- 3Points
 - Source and Destination Indicator Identified (1 point)
 - Component Identified (1 point)
 - Failure type (1 point)
- 2Points
 - Source and Destination Indicator Identified (1 point)
 - Component Identified (1 point)
- 1 Point
 - **Source and Destination Indicator** Identified (1 point)
- 0Point
 - Nothing identified

READABILITY


To measure the clarity of the alert for a detector, it needs to be human readable and can return meaningful information to the operators or anyone viewing the alert. Not everyone is trained in the art of reading alerts through network information or process specific jargons.

- Using Flesch-Kincaid formula, we can calculate the score.

- Readability Measurement:

- × Flesch-Kincaid Score 70.0 - 100.0 (4 points)
- × Flesch-Kincaid Score 50.0 - 69.9 (3 points)
- × Flesch-Kincaid Score 30.0 - 49.9 (2 points)
- × Flesch-Kincaid Score 10.0 - 29.9 (1 points)
- × Flesch-Kincaid Score 0.0 - 9.9 (0 points)

- <https://readable.com/readability/flesch-reading-ease-flesch-kincaid-grade-level/>



The graphic features a rounded rectangular box with a light blue border. At the top left is a pink square with a white letter 'R' followed by the word 'readable' in a sans-serif font. Below this, the text 'Flesch Kincaid Grade Level' is written in a large, bold, blue font. At the bottom, the formula is displayed: $0.39 \left(\frac{\text{total words}}{\text{total sentences}} \right) + 11.8 \left(\frac{\text{total syllables}}{\text{total words}} \right) - 15.59$. The numbers 0.39, 11.8, and 15.59 are in a smaller blue font, while the fractions are in a larger blue font.

ACCURACY

- Accuracy Measurement is done based on whether the solution can precisely detect the attacks done on the system and does not generate False alarms.
- Accuracy Performance Measurement:
 - × 90.0 - 100.0% Accuracy and 0.0 - 10.0 % False Alarm Rate (4 points)
 - × 70.0 - 89.9% Accuracy and 10.1 - 30.0 % False Alarm Rate (3 points)
 - × 30.0 - 49.9% Accuracy and 50.1 - 70.0 % False Alarm Rate (2 points)
 - × 10.0 - 29.9% Accuracy and 70.1 - 90.0 % False Alarm Rate (1 points)
 - × 0.0 - 9.9% Accuracy and 90.1 - 100.0 % False Alarm Rate (0 points)

RESPONSIVENESS

Detectors are supposed to alert the operators promptly to prevent permanent damage to the system. It is agreed that generally the sooner the operators are alerted the better.

Responsiveness Measurement:

- Within 5 seconds (4 points)
- Within 30 seconds (3 points)
- Within 5 minutes (2 points)
- Within 60 minutes (1 points)
- Not detected (0 points)

DISRUPTIVITY

A measure of a detector would also be on how intrusive the it would be when detecting any anomalies in the system. If the detector breaks the system then it would lead to a pretty bad situation, therefore we need to make sure that the solution does not break the system.

How this category will be calculated would be a ratio of the system downtime due to detector and total system uptime.

Disruptivity Measurement:

- Never breaks the system. (4 points)
- Disrupts the system 1- 20% of the time (3 points)
- Disrupts 21 - 50% of the time (2 points)
- Disrupts 51 - 99% of the time (1 points)
- Always breaks the system (0 points)



Q&A

THANK YOU

